

Answers to Questions received with reference to Bid, dated 13th March 2024, Installing
Aluminium Partition & Kitchen Cupboards (4th & 5th Floor of Waste Department)

19th March 2024

Please find below answers for clarification for the above bid.

1. We want to know if the partition doors are tempered glass or frame with glass.
 - a. Please use 5 mm Clear Glass.

2. Regarding the (IUL)438-AU/1/2024/10.
The Details (Measurements) of Partitions given in Information Sheet &
Measurements of Drawing Sheet does not match, so please let us know which one to
follow
 - a. Please follow the information sheet.

Procurement Section

Ministry of Climate Change, Environment and Energy
Green Building, Handhuvaree Hingun, Maafannu
Male', 20392, Republic of Maldives
Email: procurement@environment.gov.mv
Cc: logistics@environment.gov.mv
Website: www.environment.gov.mv